

The South Harrison Township School District is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for the South Harrison Township School drinking water locations was performed in February 2025. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15 micrograms per Liter ($\mu\text{g/L}$). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains and sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected, nor designed to be used for, water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet.

A summary of each location above the action level, as well as the short-term response, is found below:

South Harrison Township School

SAMPLE LOCATION	FIRST DRAW RESULT	SHORT TERM RESPONSE
Sink – Faculty Workroom	57.2 $\mu\text{g/L}$	Taken out of service

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466**LIMS Reference ID:** AD09466**EMSL Customer ID:** EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: South Harrison Lead Water Sampling

Customer PO: 24-2264
EMSL Sales Rep: Justin Monturano
Received: 02/13/2025 11:00
Reported: 02/27/2025 17:02

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SHE-FB Lims Reference ID: AD09466-01 Matrix: Drinking Water Sampled: 02/01/25 07:33:00									
Metals									
Lead	ND		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A128 Lims Reference ID: AD09466-02 Matrix: Drinking Water Sampled: 02/01/25 07:33:00									
Metals									
Lead	8.35		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A133R Lims Reference ID: AD09466-04 Matrix: Drinking Water Sampled: 02/01/25 07:35:00									
Metals									
Lead	3.28		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A133L Lims Reference ID: AD09466-06 Matrix: Drinking Water Sampled: 02/01/25 07:37:00									
Metals									
Lead	2.95		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-135R Lims Reference ID: AD09466-08 Matrix: Drinking Water Sampled: 02/01/25 07:39:00									
Metals									
Lead	4.26		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-A135L Lims Reference ID: AD09466-10 Matrix: Drinking Water Sampled: 02/01/25 07:41:00									
Metals									
Lead	3.12		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-A138L Lims Reference ID: AD09466-12 Matrix: Drinking Water Sampled: 02/01/25 07:43:00									
Metals									
Lead	2.55		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A138R Lims Reference ID: AD09466-14 Matrix: Drinking Water Sampled: 02/01/25 07:45:00									
Metals									
Lead	1.48		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A142 Lims Reference ID: AD09466-16 Matrix: Drinking Water Sampled: 02/01/25 07:48:00									
Metals									
Lead	1.96		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:49	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466**LIMS Reference ID:** AD09466**EMSL Customer ID:** EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: South Harrison Lead Water Sampling

Customer PO: 24-2264
EMSL Sales Rep: Justin Monturano
Received: 02/13/2025 11:00
Reported: 02/27/2025 17:02

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SHE-SO-A-143 Lims Reference ID: AD09466-18 Matrix: Drinking Water Sampled: 02/01/25 07:50:00									
Metals									
Lead	1.21		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A145 Lims Reference ID: AD09466-20 Matrix: Drinking Water Sampled: 02/01/25 07:52:00									
Metals									
Lead	1.84		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-CST Lims Reference ID: AD09466-22 Matrix: Drinking Water Sampled: 02/01/25 07:55:00									
Metals									
Lead	1.45		1	1.00	µg/L	02/17/25 13:56	02/24/25 12:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-BF-Hall2 Lims Reference ID: AD09466-24 Matrix: Drinking Water Sampled: 02/01/25 07:57:00									
Metals									
Lead	ND		1	1.00	µg/L	02/17/25 13:46	02/18/25 21:39	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: SHE-DW-A116 Lims Reference ID: AD09466-25 Matrix: Drinking Water Sampled: 02/01/25 07:58:00									
Metals									
Lead	ND		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-Main Lims Reference ID: AD09466-27 Matrix: Drinking Water Sampled: 02/01/25 08:00:00									
Metals									
Lead	7.46		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-Board Lims Reference ID: AD09466-29 Matrix: Drinking Water Sampled: 02/01/25 08:02:00									
Metals									
Lead	6.60		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-WC-GymR Lims Reference ID: AD09466-31 Matrix: Drinking Water Sampled: 02/01/25 08:05:00									
Metals									
Lead	ND		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-WC-GymL Lims Reference ID: AD09466-32 Matrix: Drinking Water Sampled: 02/01/25 08:05:00									
Metals									
Lead	ND		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:13	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466**LIMS Reference ID:** AD09466**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

South Harrison Lead Water Sampling

Customer PO:

24-2264

EMSL Sales Rep:

Justin Monturano

Received:

02/13/2025 11:00

Reported:

02/27/2025 17:02

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SHE-SO-FacWR Lims Reference ID: AD09466-33 Matrix: Drinking Water Sampled: 02/01/25 08:07:00									
Metals									
Lead	57.2		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-FacWR Flush Lims Reference ID: AD09466-34 Matrix: Drinking Water Sampled: 02/01/25 08:08:00									
Metals									
Lead	1.61		1	1.00	µg/L	02/25/25 16:52	02/27/25 03:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-B107 Lims Reference ID: AD09466-35 Matrix: Drinking Water Sampled: 02/01/25 08:09:00									
Metals									
Lead	4.46		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-B112 Lims Reference ID: AD09466-37 Matrix: Drinking Water Sampled: 02/01/25 08:11:00									
Metals									
Lead	1.93		1	1.00	µg/L	02/17/25 13:56	02/24/25 13:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-B127 Lims Reference ID: AD09466-39 Matrix: Drinking Water Sampled: 02/01/25 08:13:00									
Metals									
Lead	3.38		1	1.00	µg/L	02/17/25 14:03	02/24/25 13:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-B126 Lims Reference ID: AD09466-41 Matrix: Drinking Water Sampled: 02/01/25 08:15:00									
Metals									
Lead	4.12		1	1.00	µg/L	02/17/25 14:03	02/24/25 13:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-B128 Lims Reference ID: AD09466-43 Matrix: Drinking Water Sampled: 02/01/25 08:17:00									
Metals									
Lead	3.32		1	1.00	µg/L	02/17/25 14:03	02/24/25 13:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-NurRR Lims Reference ID: AD09466-45 Matrix: Drinking Water Sampled: 02/01/25 08:19:00									
Metals									
Lead	2.50		1	1.00	µg/L	02/17/25 14:03	02/24/25 13:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-Nur Lims Reference ID: AD09466-47 Matrix: Drinking Water Sampled: 02/01/25 08:21:00									
Metals									
Lead	2.59		1	1.00	µg/L	02/17/25 14:03	02/24/25 13:54	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466
LIMS Reference ID: AD09466
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: South Harrison Lead Water Sampling

Customer PO: 24-2264
EMSL Sales Rep: Justin Monturano
Received: 02/13/2025 11:00
Reported: 02/27/2025 17:02

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SHE-DW-A159 Lims Reference ID: AD09466-49 Matrix: Drinking Water Sampled: 02/01/25 08:23:00									
Metals									
Lead	2.16	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A161 Lims Reference ID: AD09466-51 Matrix: Drinking Water Sampled: 02/01/25 08:25:00									
Metals									
Lead	1.98	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-A162 Lims Reference ID: AD09466-53 Matrix: Drinking Water Sampled: 02/01/25 08:27:00									
Metals									
Lead	2.69	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A163 Lims Reference ID: AD09466-55 Matrix: Drinking Water Sampled: 02/01/25 08:29:00									
Metals									
Lead	4.86	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A164 Lims Reference ID: AD09466-57 Matrix: Drinking Water Sampled: 02/01/25 08:31:00									
Metals									
Lead	1.39	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A165 Lims Reference ID: AD09466-59 Matrix: Drinking Water Sampled: 02/01/25 08:33:00									
Metals									
Lead	ND	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-A167 Lims Reference ID: AD09466-61 Matrix: Drinking Water Sampled: 02/01/25 08:35:00									
Metals									
Lead	3.75	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-B142 Lims Reference ID: AD09466-63 Matrix: Drinking Water Sampled: 02/01/25 08:37:00									
Metals									
Lead	2.63	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-B143 Lims Reference ID: AD09466-65 Matrix: Drinking Water Sampled: 02/01/25 08:39:00									
Metals									
Lead	ND	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:33	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466**LIMS Reference ID:** AD09466**EMSL Customer ID:** EPIC62**Attention:** James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

South Harrison Lead Water Sampling

Customer PO:

24-2264

EMSL Sales Rep:

Justin Monturano

Received:

02/13/2025 11:00

Reported:

02/27/2025 17:02

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SHE-SO-Lib Lims Reference ID: AD09466-67 Matrix: Drinking Water Sampled: 02/01/25 08:41:00									
Metals									
Lead	5.20	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-DW-B144 Lims Reference ID: AD09466-69 Matrix: Drinking Water Sampled: 02/01/25 08:43:00									
Metals									
Lead	ND	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-WC-Hall3L Lims Reference ID: AD09466-71 Matrix: Drinking Water Sampled: 02/01/25 08:46:00									
Metals									
Lead	ND	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-WC-Hall3R Lims Reference ID: AD09466-72 Matrix: Drinking Water Sampled: 02/01/25 08:46:00									
Metals									
Lead	ND	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-FacLR Lims Reference ID: AD09466-73 Matrix: Drinking Water Sampled: 02/01/25 08:47:00									
Metals									
Lead	8.71	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-Kit1 Lims Reference ID: AD09466-75 Matrix: Drinking Water Sampled: 02/01/25 08:49:00									
Metals									
Lead	4.65	1	1.00		µg/L	02/17/25 14:03	02/24/25 15:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-SO-Kit2 Lims Reference ID: AD09466-77 Matrix: Drinking Water Sampled: 02/01/25 08:51:00									
Metals									
Lead	2.29	1	1.00		µg/L	02/18/25 15:50	02/19/25 09:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-ST-Kit Lims Reference ID: AD09466-79 Matrix: Drinking Water Sampled: 02/01/25 08:53:00									
Metals									
Lead	ND	1	1.00		µg/L	02/18/25 15:50	02/19/25 09:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SHE-IM-Kit Lims Reference ID: AD09466-81 Matrix: Drinking Water Sampled: 02/01/25 08:55:00									
Metals									
Lead	ND	1	1.00		µg/L	02/18/25 15:50	02/19/25 09:11	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466**LIMS Reference ID:** AD09466**EMSL Customer ID:** EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: South Harrison Lead Water Sampling

Customer PO: 24-2264
EMSL Sales Rep: Justin Monturano
Received: 02/13/2025 11:00
Reported: 02/27/2025 17:02

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

EPA 200.8 in Drinking Water

Lead	NJDEP
------	-------

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	03/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012509466**LIMS Reference ID:** AD09466**EMSL Customer ID:** EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: South Harrison Lead Water Sampling

Customer PO: 24-2264
EMSL Sales Rep: Justin Monturano
Received: 02/13/2025 11:00
Reported: 02/27/2025 17:02

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

EMSL Order Number (Lab Use Only):
AD0946

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC			
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts			
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road			
City: Pittsgrove		State/Province: NJ		Zip/Postal Code: 08318		City: Pittsgrove	
Phone: 856-205-1077		Fax:		Phone: 856-205-1077		Fax:	
Project Name: <u>South Houson Lead Water Sampling</u>				Email Results To: <u>jeberts@epicenviro.com / teberts@epicenviro.com</u>			
U.S. State where Samples Collected: NJ				Purchase Order: <u>24-2264</u>			
Number of Samples in Shipment: <u>81</u>				Date of Shipment: <u>2/13/25</u>			
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):				Samples Collected by: EMSL ☐ Client ☒ check one			
Standard Turnaround Time: ☐ 2 Weeks				The following TATs are subject to lab approval ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day			
Failure to complete will hinder processing of samples				List Test(s) Needed			
Client Sample ID	Comp	Grab	Collect Date/Time	Matrix	Preservative	EPA	Comments
SHE -FB	☐	☒	2/11/25 N/A	W=Water S=Soil A=Air SL=Sludge O=Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	200.8	Field Blank
SHE-DW-A128	☐	☒	0733	W			
↓ (FLUSH)	☐	☒	0734	W			Flush
SHE-DW-A133R	☐	☒	0735	W			
↓ (FLUSH)	☐	☒	0736	W			Flush
Released By (Signature) <u>Casey Lyons</u>				Received By <u>Thornell</u>			
Date & Time <u>2/15/25 1:00</u>				Date & Time <u>2/13/25 11am</u>			

Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other _____

Instructions or Comments: _____

Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.

Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb

Field pH: Reid P.H.O.S.

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY + PRODUCTS + TRAINING
EMSL ANALYTICAL, INC.
LABORATORY + PRODUCTS + TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD09466

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples	Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed	Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	Comments
	SHE-DW-A133L	☐	☐	2/11/25 0737	W	2							
	↓ (Flush)	☐	☐	0738	W								Flush
	SHE-DW-A135R	☐	☐	0739	W								
	↓ (Flush)	☐	☐	0740	W								Flush
	SHE-SO-A135L	☐	☐	0741	W								
	↓ (Flush)	☐	☐	0742	W								Flush
	SHE-SO-A138L	☐	☐	0743	W								
	↓ (Flush)	☐	☐	0744	W								Flush
	SHE-DW-A138R	☐	☐	0745	W								
	↓ (Flush)	☐	☐	0746	W								Flush
	SHE-DW-A142	☐	☐	0748	W								
	↓ (Flush)	☐	☐	0749	W								Flush
	SHE-SO-A143	☐	☐	0750	W								
	↓ (Flush)	☐	☐	0751	W								Flush
	SHE-DW-A145	☐	☐	0752	W								
	↓ (Flush)	☐	☐	0753	W								Flush
	SHE-SO-QST	☐	☐	0755	W								

(Lab) Received Temperature: °C



EMSL ANALYTICAL, INC.
LABORATORY + PRODUCTS + TRAINING
EMSL ANALYTICAL, INC.
LABORATORY + PRODUCTS + TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

41009466

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
							Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
SHE-SO-CST (Flush)	☐	☐	2/1/25 0756	W	2							Flush
SHE-BE-HALL2	☐	☐	0757	W								
SHE-DW-A116	☐	☐	0758	W								
↓ (Flush)	☐	☐	0759	W								Flush
SHE-SO-MAIN	☐	☐	0800	W								
↓ (Flush)	☐	☐	0801	W								Flush
SHE-SO-BOARD	☐	☐	0802	W								
↓ (Flush)	☐	☐	0803	W								Flush
SHE-WC-GYM	☐	☐	0805	W								
SHE-WC-GYM	☐	☐	0805	W								
SHE-SO-EACWR	☐	☐	0807	W								
↓ (Flush)	☐	☐	0808	W								Flush
SHE-SO-B107	☐	☐	0809	W								
↓ (Flush)	☐	☐	0810	W								Flush
SHE-DW-B112	☐	☐	0811	W								
↓ (Flush)	☐	☐	0812	W								Flush
SHE-SO-B127	☐	☐	0813	W								

(Lab) Received Temperature: °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

A009466

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8	List Test(s) Needed				Comments	
							Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time		
SHE-SO-B127 (Flush)	☐	☐	2/1/25 0814	W	2							Flush
SHE-SO-B126	☐	☐	0815	W								Flush
↓ (Flush)	☐	☐	0816	W								Flush
SHE-DW-B128	☐	☐	0817	W								Flush
↓ (Flush)	☐	☐	0818	W								Flush
SHE-SO-NVR22	☐	☐	0819	W								Flush
↓ (Flush)	☐	☐	0820	W								Flush
SHE-SO-NVR	☐	☐	0821	W								Flush
↓ (Flush)	☐	☐	0822	W								Flush
SHE-DW-A159	☐	☐	0823	W								Flush
↓ (Flush)	☐	☐	0824	W								Flush
SHE-DW-A161	☐	☐	0825	W								Flush
↓ (Flush)	☐	☐	0826	W								Flush
SHE-SO-A162	☐	☐	0827	W								Flush
↓ (Flush)	☐	☐	0828	W								Flush
SHE-DW-A163	☐	☐	0829	W								Flush
↓ (Flush)	☐	☐	0830	W								Flush

(Lab) Received Temperature: °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS • TRAINING
EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD09466

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Client Sample ID	Comp	Grab	Collect Date/Time	Matrix W=Water S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	List Test(s) Needed				Comments		
						EPA 200. 8	Field pH	Field pH Test Time	Field Temp Deg C		Field Temp Test Time	
SHE-DW-A164 ↓ (Flush)	☐	☐	2/1/25 0831 0832	W	2							Flush
SHE-DW-A165 ↓ (Flush)	☐	☐	0833 0834	W								Flush
SHE-DW-A167 ↓ (Flush)	☐	☐	0835 0836	W								Flush
SHE-DW-B142 ↓ (Flush)	☐	☐	0837 0838	W								Flush
SHE-DW-B143 ↓ (Flush)	☐	☐	0839 0840	W								Flush
SHE-SO-L1B ↓ (Flush)	☐	☐	0841 0842	W								Flush
SHE-DW-B144 ↓ (Flush)	☐	☐	0843 0844	W								Flush
SHE-WC-HAL3L ↓ (Flush)	☐	☐	0846 0846	W								Flush
SHE-WC-HAL3R ↓ (Flush)	☐	☐	0847 0847	W								Flush

(Lab) Received Temperature: °C



**Environmental Chemistry
Chain of Custody**
EMSL Order Number (Lab Use Only):

AD09466

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

[illegible]

(Lab) Received Temperature: _____ °C